



NOTES

1. LINE CONDUIT MUST BE SCHEDULE 80 PVC OR RIGID GALVANIZED. COORDINATE SIZE AND NUMBER OF CONDUITS WITH UNITED POWER.
2. MAIN DISCONNECT MAY BE REQUIRED ON THE LINE SIDE OF ANY GROUP OF SIX METERS TO COMPLY WITH NEC, STATE OR LOCAL CODES.
3. SOCKET JAWS MUST BE A MINIMUM OF 125 AMPS. FIFTH TERMINAL TO BE IN 9:00 POSITION AND MUST BE GROUNDED.
4. LOAD CONDUCTORS MAY EXIT EITHER TOP OR BOTTOM OF TENANT BREAKER SECTION. THEY SHALL NOT TRAVEL THROUGH OR EXIT OUT OF SOCKET SECTION OF MODULES.
5. THREE-PHASE SERVICES WILL NOT BE ADDED TO THIS GEAR AFTER INITIAL INSTALLATION UNLESS GEAR WAS DESIGNED AND MANUFACTURED FOR THAT USE AND APPROVED IN ADVANCE BY UNITED POWER.
6. EACH METER MUST BE IDENTIFIED WITH A BRASS TAG DESIGNATING THE PROPER APARTMENT UNIT NUMBER OR ADDRESS.
7. LINE BUS FEED MUST HAVE BARRIER WHEN PASSING THROUGH TENANT BREAKER SECTION FOR SAFETY AND SECURITY.
8. TOP METER SHALL BE A MAXIMUM OF 72 INCHES FROM FINISHED GRADE. BOTTOM METER SHALL BE A MINIMUM OF 18" FROM FINISHED GRADE.
9. UNITED POWER REQUIRES A METER CLEARANCE OF 36 INCHES MINIMUM BETWEEN THE FRONT OF SOCKETS AND ANY WALL OR OBSTRUCTION.
10. ALL LINE FEED SECTIONS SHALL BE LOCKABLE AND SEALABLE BY UNITED POWER.
11. ALL UNITS SHALL BE COMPLETE WITH SOCKETS AND BREAKERS AT THE TIME OF INITIAL SET OF THE FIRST METER.
12. GUARD POSTS (BOLLARDS) SHALL BE REQUIRED IN TRAFFIC AREAS.
13. THIS INSTALLATION FOR RESIDENTIAL USE ONLY.

ISSUED	
APPROVAL	<i>[Signature]</i>
APPROVAL	
DATE	BY
	REVISIONS

UNITEDPOWER

UNITED POWER, INC.
P.O. BOX 929 • BRIGHTON, CO. 80601

120/208V FIVE TERMINAL MODULAR
APARTMENT HOUSE METERING